

Gummiwerk Kraiburg GmbH & Co.KG
Teplitzer Straße 20
D – 84478 Waldkraiburg

Test Certificate

based on EN 16421:2015 method 2

„Influence of materials on water for human consumption —
Enhancement of microbial growth (EMG)”

Producer: Delifer Enerji Hizmetleri san.tic.ltd.şti.
Product(s): Test Plates 20cm*20cm
Material: AA5KWZ
Type of test: EN 16421:2015 method 2

According to OFI test report No. 1802096 / 6368 / 1H from 2019-04-03 the above mentioned material was tested according to EN 16421:2015 method 2.

Based on these test results and with due regard to the requirements given in the technical rule of DVGW worksheet W 270:2007, the material

“AA5KWZ”

is suitable for direct contact with drinking water with respect to microbial growth when used as small-area seals – on condition of professional processing with respect to its application.

The **validity of this test certificate** ends with **2024-04-03** – this under the presumption that no changes in the production or manufacturing process or the basic material are made, with the exception of routine adjustments; in case of changes in the relevant legislations and/or normative regulations, which require a new test on the product, this test certificate loses its validity.

Vienna, 2019-08-05



Christoph Wirrer, BSc
Director in charge
Materials in contact with drinking water